

Lund Waterworks District

***SMALL WATER SYSTEM AND DAM
EMERGENCY RESPONSE PLAN***

Table of Contents

Page 3	Location of Water Sources
Page 4	Emergency Contact Information
Page 6	In Case of Emergency
Page 7	Types of Emergencies
Page 8	Appendix Photos
Page 9	Emergency Response Plan
Page 13	Emergency Plan
Page 14	Location of Equipment
Page 15	Schematic Drawing/ Maps
Page 16	List of Available Equipment and Tradespeople
Page 18	Telephone Tree

LOCATION OF WATER SOURCE(S):

Thulin Lake Dam / Pump House

Directions to Site: 9730 Emil Road (near the end), Emil is the first road on the right off of Finn Bay Road, behind Lund Automotive & Outboard

GPS Settings Pump House:

Latitude - 49°58'53.69" N

Longitude - 124°45'12.99" W

Water Licence File Numbers:

Thulin Lake Dam	D420152
Thulin Lake (2 nd Lake aka Lund Lake) Dam	D420144
Water Premises Number	1110436
Small Water Systems Certificate Number	746

EMERGENCY CONTACT INFORMATION

LUND WATERWORKS DISTRICT EMERGENCY CONTACTS

<u>CONTACT NAMES</u>	<u>PHONE #</u>	<u>CELL #</u>	<u>FAX/ OTHER</u>	<u>EMAIL</u>
LWD Administrator: Kelly Rankin		604-781-4687		lundwaterdistrict@gmail.com
LWD Certified Operator Courtney Robertson EOCP #: 8490	604-414-0230	604-483-1410		courtney.robertson808@gmail.com
LWD Receiver: Frances Ladret		604-223-4671		francesladret@gmail.com
Catastrophic Emergencies: Ria Curtis	604-414-0383			littlewingfarm@telus.net
Emergency Notification System: (24 hr access) Ryan Thoms	604-485-2260	604-414-4553	604-485-2216	emergency@qathet.ca

VANCOUVER COASTAL HEALTH AUTHORITY CONTACTS

Drinking Water Officer Jack Davidson, EHO/DWO	604-485-3335	604-483-1981	604-314-0596	Jack.davidson@vch.ca
Back-Up Health Contacts: Darren Molder SEHO/DWO	604-885-8711	604-989-1357	604-885-5200	Darren.molder@vch.ca
Michael Nguyen EHO/DWO	604-485-3335	604-414-5545	778-317-8567	Michael.nguyen@vch.ca
Medical Health Officer: Moliehi Khaketla MHO	604-984-5070	604-612-9433		Moliehi.khaketla1@vch.ca
Back-up Health Contact: Mark Ritson, EHO/DWO Manager Health Protection	604-983-6751	604-219-7359	604-988-6516	Mark.ritson@vch.ca

OTHER GOVERNMENT CONTACTS

Dam Safety Officer Ministry of Forest Lands & Natural Resources Surrey Office: Binod Acharya	778-572-2183	604-226-5130	604-586-4434	Binod.Acharya@gov.bc.ca
Dam Safety Section Head Ministry of Forest Lands & Natural Resources HQ Victoria: Scott Morgan	250-387-3265		604-356-0605	scott.morgan@gov.bc.ca
Conservation Officer Service: Leyland Klassen	236-468-3658		877-952-7277	leyland.klassen@gov.bc.ca
Ministry of Transportation & Highways Powell River: Rino Parise	604-485-3610	604-483-1189		Rino.Parise@gov.bc.ca
Ministry of Forest Lands & Natural Resources Natural Resource Officer – Tony Carroll or Hugo Sloos	604-485-0729	604-485-0700	604-485-0785	
Department of Fisheries and Oceans - Powell River Office	604-485-7963			

PUBLIC HEALTH CONTACTS

Drinking Water Officer: Jack Davidson	604-485-3335	604-483-1981	604-314-0596	Jack.davidson@vch.ca
Back-up Health Contact: Darren Molder	604-885-8711	604-989-1357	604-885-5200	Darren.molder@vch.ca
Back-up Health Contact: Michael Nguyen	604-485-3335	604-414-5545	778-317-8567	Michael.nguyen@vch.ca
Medical Health Officer: Moliehi Khaketla	604-984-5070	604-612-9433		Moliehi.khaketla1@vch.ca

LOCAL CONTACTS / PROPERTY OWNER(S)

Tla'amin Nation: Jenny Freeman – upland property owner around the lakes and dams	604-413-6828 ext. 137	778-212-3506	604-483-9769	jenny.freeman@tn-bc.ca
----------------------------------------------------------------------------------	-----------------------	--------------	--------------	--------------------------------------------------------------------

IN CASE OF EMERGENCY:

If the water in the water system becomes contaminated or you receive an unsatisfactory water result, or in the event of an interruption in the treatment process:

1. Shut off the water supply, if appropriate.
2. **Courtney Robertson** will notify DWO (Jack Davidson) or other back-up health contact.
3. Contact other appropriate person(s) from the list of emergency numbers.
4. **Kelly Rankin / Emergency Notification System (if needed)** will notify any affected water users. Please keep a phone and address list of users and warning signs handy. May need to phone (and water disinfection procedures) to the users.
5. **Courtney Robertson** will post 'Boil Water Advisory' signs and hand deliver any notices as required.
6. **Courtney Robertson** will coordinate repair.
7. Organize alternate source of safe drinking water (if available).

Start-up Procedure

1. Identify and correct source of contamination.
2. Entire system should be flushed and disinfected. Follow attached guideline.
3. Submit water sample(s) to appropriate approved lab for testing. For bacteriological contamination, 3 negative successive samples are usually required. Contact your DWO to confirm the number of samples necessary.
4. Contact DWO for approval to resume use of water supply.

Posting the Emergency Response Plan

The ERP must be posted in a conspicuous location that is easily accessible to the operator and management of the water supply.

Location of ERP: Main pump house – 9730 Emil Road

Additional Information

1. Include schematic drawing of the water supply system; from the source to the tap. Include all sources, storage, reservoirs, and treatment and distribution system.
2. Include public notices which may be required in the event of a "boil advisory" or "do not consume" notice.

TYPES OF EMERGENCIES:

Boil Water Advisories

Dam Seepage Advisories

Contact property residences adversely affected by dam breach

Equipment Failures

Dam Failures

Medical Emergencies – BC Ambulance Service, Paramedic evacuations

Preplan:

The scope of this plan is to provide relevant information to both water users and applicable government agencies.

We will be using the **Incident Command System** for ALL emergency situations. It is a flexible system for all types of incidents. It incorporates and falls into line with the Provincial Emergency Protocols that all emergency agencies use in the Province of BC.

1. We will be working closely with Ryan Thoms, the qathet Regional District Manager of Emergency Services & Ria Curtis, Emergency Social Services.
2. We will be using the qathet Regional District Emergency Notification System as an initial call out for all emergency/catastrophic situations.

Contact Information List:

1. Contact information for various Government regulatory staff, LWD Receiver, Contracted Water System Operator, and LWD Administrator.
2. Contact information of Lund community residence using Emergency Notification System and all appropriate means to provide information, e.g. sandwich board signage, posting notices at the Post Office, Hotel, Wharfinger Building, contacting by phone those not on the Emergency Notification System.

Appendix Photographs:



Located at Dam behind the Main Pump House



Main Pump House – Located at 9730 Emil Road, Lund, BC

May 2025

Lund Waterworks District Emergency Response Plan

The Lund Waterworks District Emergency Response Plan considers three levels of emergencies for the water distribution system and for the water storage system:

1. Real or potential threat to facilities or watershed.
2. Impact on a single component of, or a temporary impact on the water distribution system, or incursions into the water storage.
3. Disaster.

Requirements

The Receiver and LWD staff will have a kit, which contains:

- The Emergency Response Plan
- The latest list of users, including telephone numbers, and back-up contact numbers. In all cases, users contacted will be documented; a notice will be delivered to users who were not at home.
- Keys to all facilities of the system
- List of regulatory authority notification

Emergency Levels

Level 1 - Minimal or potential for impact on service

Water Distribution

- Main breaks which affect users on a single node of the system
- High bacterial counts on a single branch of the system
- Booster pump failure, Larson Road zone

Dams and Watershed

- Animal activity which obstructs downstream of dams
- Animal activity on the lakes
- Intrusions into the watershed or dams
- Exceptional run-offs

Level 2 - Service Impact

Water Distribution

- System power failure
- Contamination: cross-connection, back-flows, main breaks. High or fecal coliform counts
- Covert or inadvertent damage to storage

Dams and Watershed

- Pollution from waste
- Landslides
- Minor seismic events
- Animal activity blocks water course

Level 3 - Disaster

Water Distribution

- Disease outbreak
- Major power failure
- Earthquake damage

Dams and Watershed

- Full dam breach from major seismic events
- Blockage of water course(s) from accidents or seismic events

Response

Level 1

Water Distribution

- Notify users local to area affected: relay immediate or potential impact, including the remedies required to correct the problem.
- Issue a boil advisory in the case of quality upset or main breaks.
- Put out Boil Water Advisory sandwich boards.
- For the Larson Rd. pressure zone: Loss of level in Number 3 reservoir may mean that the pump set has failed, that the level control has failed, or that the power supplied has failed. Troubleshoot by attempting to start the pump by the manual override. If the pump does not run, enlist Administrator or Receiver to mobilize an electrician, set up a pumper-truck to refill Number 3 reservoir, and to organize repairs.

Dams and Watersheds

Animal Activity:

- Notify Highway Maintenance if Emil Road or Highway 101 Highway culverts are blocked
- Notify Conservation Officer, get approval to relocate or trap animal(s).

Intrusions

- Notify RCMP
- Notify Conservation Officer, get approval to relocate or trap animal(s).

Level 2

Water Distribution

Contamination

- Notify Safe Drinking Water Officer, Jack Davidson
- Issue a boil water advisory to users and put out the Boil Water Advisory signs
- Set up telephone tree
- Take samples, flush system

Dams and Watershed

Pollution

- Notify Jack Davidson and Conservation Officer.
- Set up telephone tree and notify users via Emergency Notification System as needed
- Flush water systems
- Issue boil advisory
- Set up a committee of Receiver and LWD staff to deal with the situation
- Get professional assistance as required

Level 3

Response Management

- The Receiver or Administrator, who receives the call, immediately sets up the telephone tree to notify the users and businesses immediately affected /requests to qRD and/or Ryan Thoms to add additional notice via Emergency Notification System. In the case of dam failure/flooding evacuate the downstream residences & businesses.
- The command center will be Frances Ladret's residence at 1469 Sorenson Road, Lund, BC.

Organization

1. The Water Operator will be the Incident Commander.
2. The Administrator will be assigned to confirm that affected residences and businesses comply with required actions.
3. Local radio stations, the RCMP, the Drinking Water Protection Officer, and the Surrey Dam Safety Officer will be notified.
4. In the event that the dams are damaged, the highways contractor will be requested to assist.
5. Contact Dam Safety Officer.

Post Emergency Recovery Planning

The Water Operator will focus on restoring service, if at all possible.

The next step will be to evaluate the extent of the damage, then:

1. Get professional advice in evaluating the damage.
2. Arrange for contractors to repair the damage.
3. Get professional assistance to make permanent repairs.

EMERGENCY PLAN

EMERGENCY	CONTACT	ACTION
<ul style="list-style-type: none"> ▪ Power Failure 	<ul style="list-style-type: none"> ▪ Water Operator ▪ Administrator ▪ Receiver 	<ul style="list-style-type: none"> ▪ Switch Pump house auxiliaries to the inverter. ▪ Maintain tank levels with gas auxiliary pump. ▪ Monitor water system chlorine residual. ▪ Shot feed Number 2 & 3 reservoirs if CHL residual less than 0.1.
<ul style="list-style-type: none"> ▪ Security ▪ Misuse of Watershed resulting in potential water contamination. 	<ul style="list-style-type: none"> ▪ RCMP ▪ Water Operator ▪ Administrator ▪ Receiver 	<ul style="list-style-type: none"> ▪ 604-485-6255 ▪ Communicate with offender. ▪ Contact Authorities <ul style="list-style-type: none"> ➤ Water Protection Officer, Dan Glover. ➤ RCMP ➤ Forest Service ➤ Regional District ➤ Conservation Officer
<ul style="list-style-type: none"> ▪ Coliform Contamination 10 is normal Alarm is 20 	<ul style="list-style-type: none"> ▪ Water Operator ▪ Administrator ▪ Receiver 	<ul style="list-style-type: none"> ▪ Notify water users of corrective action, issue boil water advisory and put out sandwich boards. ▪ Test water for chlorine content as required. ▪ Shot feed water tanks with sodium hypochlorite as required. ▪ Flush systems as required. ▪ Check for possible back flow situation. ▪ Notify users with boil water advisory. ▪ Instruction comes from Health Unit. ▪ Take follow up bacteria samples for testing.
<ul style="list-style-type: none"> ▪ Dirt in Water 	<ul style="list-style-type: none"> ▪ Operator ▪ Administrator ▪ Receiver 	<ul style="list-style-type: none"> ▪ Check and flush intake. ▪ Check/Clean pump intake filters. ▪ Flush system to remove any residual dirt. ▪ Test water for chlorine residual +0.2.
<ul style="list-style-type: none"> ▪ Water Main Failure or Water Leaking 	<ul style="list-style-type: none"> ▪ Call before you dig ▪ Operator ▪ Administrator ▪ Subtrades, if necessary ▪ Receiver 	<ul style="list-style-type: none"> ▪ 1-800-474-6886 or cell 6886 ▪ Isolate and repair under a positive pressure. ▪ Isolated area at negative pressure. Treat area with sodium hypochlorite to kill possible bacteria, flush, and test for chlorine residual. Follow up with bacteria test samples.
<ul style="list-style-type: none"> ▪ Earthquake 	<ul style="list-style-type: none"> ▪ Administrator ▪ Operator ▪ Receiver ▪ 	<ul style="list-style-type: none"> ▪ Monitor distribution system for failures. ▪ Isolate and repair where required. ▪ Check both lake dams for damage. ▪ Check water reservoirs 1, 2, and 3.
<ul style="list-style-type: none"> ▪ Medical 	<ul style="list-style-type: none"> ▪ 911 	<ul style="list-style-type: none"> ▪ Fireman 1st responder. ▪ Ambulance

LOCATION OF EQUIPMENT

Chlorine Test Kit	No. 1 Pump House (Hach Model)
Tools*	No. 1 Pump House
Spare Water Main Pipe/Fittings	No. 1 Pump House
Schematics for Water System	No. 1 Pump House
Chlorine Neutralizer	No. 1 Pump House. 40Kg Sodium Thiosulphate; 25 kg De-Chlor tablets

*List of Tools - No. 1 Pump House

1. Valve keys, wheel wrenches.
2. Small tools: pipe wrenches: crescent wrench
3. Repair collars.
4. Isolation caps/spare valves, water pipes, service pipe, and saddles.
5. Shovels, picks, and mattocks.
6. Pipe lubrication.
7. Chain block.
8. Spare water main pipe.
9. Meters and parts.
10. Forms: boil water advisories; boil notices; loss of service.
11. Reference material
 - Operations

MSDS for Sodium Hypochlorite

MSDS for Sodium Thiosulphate

MSDS for Chlorine Test Reagents

LIST OF AVAILABLE EQUIPMENT – TRADESPEOPLE

1. Electrical	BC Hydro Dillon Worthen–Lund Electric Charlie Bird-Newport Electric	1-888-769-3766 604-414-8238 604-485-0045	
2. Generator	Courtney Robertson Stored in pump house, 20L Fuel on hand	C:604-483-1410 H:604-414-0230	courtney.roberston808@gmail.com
3. Excavator	Ecoterra Developers Ltd. Dave Scherger Beartooth Excavating	604-483-9560 604-483-1487 604-414-9686	ecoterradevelopers@gmail.com garrett@beartoothexcavating.com
4. Backhoe	Ecoterra Developers Ltd. Dave Scherger Beartooth Excavating	604-483-9560 604-483-1487 604-414-9686	ecoterradevelopers@gmail.com garrett@beartoothexcavating.com
5. Pump (Dewater)	Fire hall Mike Burge	911 604-483-4544	
6. Pump Repairs & Installations	Island View Mechanical Newport Electric-Charlie Bird	604-223-0343 604-485-0343	
7. Divers	Powell River Divers	604-485-4526	
8. Plumbers	Island View Mechanical Al Stepaniuk	604-483-4988 H 604-223-0343 C	ivm@rogers.com
9. Water Operator	Courtney Robertson	604-414-0230 H 604-483-1410 C	courtney.robertson808@gmail.com
10. Equipment Supplier	Fred Surrige Pete's Plumbing	250-954-0368 604-485-9761	
11. Main Repairs & Installations/Bulk Water Suppliers	Ecoterra Developers Beartooth Excavating	604-483-9560 604-414-9686	ecoterradevelopers@gmail.com garrett@beartoothexcavating.com
12. Treatment & Chemical Metering Equipment	Smith Cameron Process Solutions	604-596-5522	
13. Sodium Hypochlorite Supplier	Aaron Vending ClearTech Industries	604-485-5611 1-800-387-7503	

*This plan has been edited by Courtney Robertson, Lund Waterworks District Water System Operator, and Kelly Rankin, Lund Waterworks District Administrator, May 22, 2025.
This is a living document, subject to updates and changes and new contacts and information as required or as government/other contacts change.*

Copies of this plan will be provided to the following individuals/organizations:

Pump house at Thulin Lake – 9730 Emil Road
Shelley Cherry, Administrator for Lund Waterworks District
Courtney Robertson, Water Operator for Lund Waterworks District
Frances Ladret, Receiver for the Lund Waterworks District
Ryan Thoms, Emergency Coordinator for qathet Regional District
Jessie MacDonald, Evacuation Planning Assistant for qathet Regional District
Jack Davidson, Drinking Water Officer for Vancouver Coastal Health
Jenny Freeman, Emergency Management Coordinator for Tla'amin Nation
Per request

Lund Waterworks District
Emergency Call Out Telephone Tree

<u>Kelly Calls:</u>		<u>Contacted?</u>
<p>1. Christine Hollmann 9675 Longacre Road 604-414-5125</p>	<p>1. Doubt, Tyler & Laperrier, Lindsey - 1308 Alannah Road - 604-223-8224 2. Hilton, Roger - 9533 Bayside Road - 604-483-4998 3. Werner, Randy - 1587 Boars Nest Road - 604-414-0322 or 604-414-4085 4. Clements, Rick & Lisa - 1599 Boars Nest Road - 604-886-4272 or 604-989-1176 5. Lennox,, Jason & Joyce - 1608 Boars Nest Road - 604-414-8073 6. Erwin, Dave & Bradley, Fern - Lot 10 Boars Nest Road - 778-788-2204 DISCONNECTED 7. Cameron, Barbara & Rochon, Ronald - 9773 Edmondson Road - 604-616-8553 8. Bradley, James - 9780 Edmondson Road - 604-413-3851 9. MacKay, Don & Rose, Paula - 9791 Edmondson Road - 604-483-3431 or 604-223-1041 10. Mercs, Paul - 10080 Finn Bay Road - 604-483-9611 11. ALW Holdings Corp - 9550 Bayside Road - 604-315-9590</p>	
<p>2. Parsla Robertson 1404 Murray Road 604-414-0710</p>	<p>1. McDowell Donna - 1272 Alannah road - 604-483-2351 2. Baird, Joy - 9559 Bayside Road - 483-7944 3. Robb, Richard & Nicole - 10038 Finn Bay Road - 510-907-0378 or 510-717-4879 4. Voltz, Tilo & Dammann, Rico - 10060 Finn Bay Road - 604-396-0304 or 236-513-6455 5. Lattimer/Firemprong/Colby/Elliott - 10088 Finn Bay Rd - 778-996-6549 or 514-206-0671 6. Lawlor, Jeffrey & Markel, Kimberly - 10118 Finn Bay Road - 604-223-5155 7. Mallery/Jeakins - 9789 Finn Bay Road - already on list - DISCONNECTED 8. Watson Wayne & Sue - 9827 Finn Bay Road - 604-483-3484 or 604-483-1508 9. Buble, Lewis (Lucy Mae Holdings) - 9821 Finn Bay Road - 604-818-9667 or 604-420-9164 10. GCRD Holdings/Elsworth - 9907& 9919 Finn Bay Rd - 604-483-3566 or 604-414-8646 11. Elsworth, Dean & Roy - 9911 Finn Bay Rd - 604-414-9964</p>	

<p>3. Frances Ladret 1469 Sorenson Road 604-483-4592</p>	<ol style="list-style-type: none"> 1. Mallery, Colin & Sharanowski, Cassidy-9541 Bayside Rd-604-483-9419 or 604-223-0573 2. Reum, Robert - 9939 Finn Bay Road - 587-343-4145 or 252-721-8087 3. Beardmore, Matthew - 9951 Finn Bay Road - 778-870-8222 or 778-834-6927 4. Jeakins, Nancy(VB Humph)-9959,9971,9973 Finn Bay Rd- 604-318-6325 or 604-414-0755 5. Harris, Amanda - 9975 Finn Bay Road - 604-414-0608 or 867-862-7408 DISCONNECTED 6. Finn Bay Marine Group Inc. (Turner, Kelli) - 9995 Finn Bay Road - 604-720-5559 7. Clausen, Paul & Ruth - 9803 Franzin Road - 604-929-5375 or 604-787-1946 8. Ulmer, Joel & Francine - 1331 Grouse Ridge Road - 604-414-0154 9. Sanderson, Dana - 1355 Grouse Ridge Road - 604-483-6944 10. Lund Water Taxi (Wood, Al & Gina) 1431 & 1672 Highway 101 - 604-483-9749 11. Clark, Dave - 1343 Grouse Ridge Road - 780-709-6746 	
<p>4. Joanne Suche 9562 Larson Road 604-483-4943</p>	<ol style="list-style-type: none"> 1. Lund Resort (Tla'Amin Res) - 1436 Highway 101 - 604-414-0474 or 604-483-3543 2. Lund Harbour - 1439 Highway 101 - 604-483-4711 3. Levy, Ed & Julia - 1457 Highway 101 - 604-483-8984 or 604-202-4810 4. Leech, David or Lawford, Karen - 1474 Highway 101 - 613-680-6806 or 613-614-7534 5. Lund Harbour Edge Holdings - 1511 Highway 101 - 604-483-4120 or 604-483-4180 6. Lund Auto & Outboard - 1520 Highway 101 - 604-483-4612 7. Burge, Mike & Lori-1548 Highway101&1401 Murray Rd- 604-483-4544 or 604-414-4929 8. Combes, Georgia & Dela Chairotiere, Ginette - 9561 Larson Road - 604-483-4827 9. Winegarden, Ted & Joan - 9505 & 9602 Larson Road - 604-483-8128 or 604-483-3496 10. Kiddey, Thomas & Pamela - 9550 Larson Road - 604-223-4142 or 403-742-9836 11. Mathieson, Ryan - 1615 Boar's Nest Road - 778-991-9426 	

<p>5. Carol Pence 9576 Larson Road 604-483-4304</p>	<ol style="list-style-type: none"> 1. Wood, Al & Gina - 9553 Larson Road - 604-483-9600 2. Uhlar, Jan & Aasen, Carly - 9557 Larson Road - 778-587-9697 or 250-883-9697 3. Rehfeldt, Herbert & Brandau, Susanne - 9573 Larson Road - 604-483-2011 4. Ogilvie, Nicole - 9584 Larson Road - 604-483-2353 or 250-937-0373 5. Horsburgh, Jennifer - 9624 Larson Road - 250-650-1828 6. Brander, Patrick & Heather - 9781 Edmondson Road - 604-905-9200 or 604-698-5857 7. Harrison, Bruce - 9577 Larson Road - 604-483-9888 8. The Boardwalk Restaurant - 9673 - Larson Road - 604-483-2201 9. Sun Lund by the Sea RV Park - 1496 Murray Road - 604-483-9220 10. Shoji, Kutz & Carol - 1480 Murray Road - 604-224-4751 or 604-732-6868 11. Maedel, Barry (1071574 BC Ltd.) - Lot E, Sevilla Island - 604-740-6931 	
<p>6. Wendy Drummond 1495 Sorenson Road 250-415-8564</p>	<ol style="list-style-type: none"> 1. Larson, Thor - 1413 Murray Road - 604-483-3255 2. Ferreira, Angus & Catharina - 1427 A&B Murray Road - 604-483-9996 3. Burgess, Sara & Alan - 1443 Murray Road - 250-898-7014 4. Bignell,, Ron & Richards, Jill - 9873 Norlund Road - 604-970-8693 or 604-910-9760 5. Larson, Wendy - 9877 Norlund Road - 604-483-7955 6. MacLean, Doug & McKee, Melise - 9910 Norlund Road - 604-483-2433 or 604-414-4317 7. Monckton, Simon & Simone - 9622 Quarry Place - 778-733-0672 or 403-594-9863 8. Bouchard, Ben & Nancy - 9624 Quarry Place - 604-483-4120 9. Mouldenhauer, Christopher & Trina - 9626 Quarry Place - 604-414-9786 or 250-615-9525 10. Gray, Evan & Kimberly - 9627 Quarry Place - 604-483-1000 11. 1071574 BC Ltd. - Lot E, Sevilla - 	

<p>7. Cheryl Walden 1411 Grouse Ridge Road 604-483-3144</p>	<ol style="list-style-type: none"> 1. Robb, Ron & Lovewell, Jan - 9644 Quarry Place - 604-483-4806 2. Cox, Robert (David - tenant) - 9649 Quarry Place - 604-414-0266 3. Clark, Ulla & Lax, Joseph (Johannes - tenant) - 9651 Quarry Place - 604-902-3636 4. Wong, Sonny & Cindy - 1530 Scotch Place - 604-414-9430 5. Saunders, Michael - 1534 & 1540 Scotch Place - 604-483-7979 6. Hernandez, Zane - 1543 Scotch Place - 604-578-0801 7. Bourdais, Tanya & Nick - 1545 Scotch Place - 604-414-9350 or 604-223-1496 8. Bacon, Matthew & Lila - 9808 Sevilla Island - 604-768-8715 or 226-343-0118 9. Markin, Donna - 9816 Sevilla Island - 604-862-3029 10. Vigh, Bela & Gardner-Vigh, Ann - 9824 Sevilla Island - 604-619-6617 or 604-812-6610 11. Leavitt, Jeffrey - 1684 Highway 101 - 604-905-0154 	
<p>8. Kimberly Burge 1401 Murray Road 604-414-4929</p>	<ol style="list-style-type: none"> 1. Barton, Ron & Sutherland, Ruth - 9832 Sevilla Island - 604-483-3195 2. Coles, Gordi & Agnew, Cindy - 9836 Sevilla Island - 604-483-1644 or 604-483-4570 3. Mckee, Bill & Huval, Renee - 9848 & 9852 Sevilla Island - 604-483-4929 4. Johnson, Janice - 9840 Sevilla Island - 604-483-4486 5. Chouinard, Gord & MaryAnne (Lund Seaside Inn) - 9844 Sevilla Island - 604-414-0097 6. Shore, Paul & Talya - 1500 Sorenson Road - 604-967-3555 7. Hennenfent, Melanie - 9570 Larson Road - 604-446-7111 8. qathet Regional District - School, Sewer Plant, Firehall - 604-485-2260 9. Johnston, Brian - 9636 Larson Road - 604-223-2324 10. McKee, Emily - 9848 Sevilla Island - 604-208-4160 11. Altamont Ent/Chen, Frank - 1549 Hwy 101 - 604-629-8566 DISCONNECTED 	